4. Classification and field of application

4.1 Reference and direct field of application

This classification has been carried out in accordance with clause 11 and 15 of EN 13501-1:2007

4.2 Classification

The product called "OOOO Model: OOO, Color: OO " in relation to fire behavior is classified:

В

The additional classification in relation to smok production is

s2

The additional classification in rel up to flaming particles/droplets is

d0

The format of the recipn to fire classification for construction products excluding floorings and linear pipe therred a sulation product is:

Fire Behaviour	Smoke Production	Flaming Droplets
В	s2	d0

Reaction to fire classification: B-s2,d0